



State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3503 FAX (603) 271-2982

September 4, 2003



Constance Coviello, Chairman
Board of Selectman
P.O. Box 119
West Stewartstown, NH 03597

**Re: Letter of Deficiency No. WD WWEB/R 03-04 of July 16, 2003
Septage Lagoons, Back Pond Road**

Dear Ms. Coviello,

On August 28th DES inspected the Town's septage lagoons on Back Pond Road to verify implementation of the corrective measures outlined in the Town's August 11th response to the Letter of Deficiency (LOD). The inspection revealed 2 feet of freeboard has been realized at the lagoons, thereby correcting the deficiency noted in the LOD.

Please instruct the operator of the lagoons to maintain the 2-foot minimum freeboard at all times.

Please call me with any questions at (603) 271-7888, or via e-mail at arastorguyeff@des.state.nh.us.

Sincerely,

Alexis Rastorguyeff, P.E.
Residuals Management Section
Wastewater Engineering Bureau

cc: file/db
John Bush, P.E. – Administrator WEB
Dick Flanders – Supervisor RMS